

PUBLIC NOTICE

The Baltimore City Department of Public Works, in coordination with EBA Engineering Inc., the Mayor Stephanie Rawlings-Blake and City Council Belinda Conaway, are accepting public review and comments for a request to issue an Utility Waiver to the City Code for Improvements to the GRD Branch Interceptor in the High Level Sewershed located at 3104 – 3304 N. Hilton Street and 3030 – 3300 Liberty Heights Ave.



Notice is hereby given that the public is invited to comment on the request by EBA Engineering Inc., 4813 Seton Drive, Baltimore, MD 21215 for a waiver of Stormwater Management (SWM) quantity and quality control requirements for improvements to the GRD Branch Interceptor Project. Comments on the request for SWM waivers must be received by 5:00 pm on August 30, 2010, to ensure consideration by the Department.

The Improvements to the GRD Branch Interceptor project is proposing replace the existing 12" and 15" sewer with a new 18" sanitary sewer and relocate an existing 20" water main. The proposed project will include installation of utilities: storm drains, water services, sanitary sewer services, on-site storm drains, water, sewer and gas house connections, replacement of existing driveways, sidewalks, ramps, curb and gutter and inlets, replacement of existing trees, shrubs, landscaping and structures to original conditions.

In order to meet the 2010 Baltimore City SWM Ordinance requirements for the proposed improvements, waivers for stormwater management water quantity and quality control are requested. The project creates no impervious areas and the project runoff is minimized by the forested areas surrounding the site. No stormwater management is required under these circumstances since no changes will be performed to the existing finished conditions.

PLAN

A copy of the Sewer Line Improvements and Water Relocation Plan may be obtained by calling and making a request to EBA Engineering Inc. 410-358-7171 or by visiting the office during normal business hours. Mr. John Tabak, EBA Engineering Inc., 4813 Seton Drive, Baltimore, MD 21215.

Waiver Comments or Questions

Notices regarding future actions on this project will be posted.

Questions or comments on the project may be submitted during the review period by email to Warren.ware@baltimorecity.gov or by mail to Mr. Warren Ware, Baltimore City Department of Public Works, Bureau of Water and Waste Water – Surface Water Division, 3001 Druid Park Drive, Baltimore, Maryland 21215